

Scope of Work Summary

Design, fabrication, shop testing, packaging, delivery and warranty of :

Supply of four (4), 24 kV (Maximum Rated Voltage), 12,000 A, 80 kA interrupting capacity generator circuit breakers complete with their control panels for each of the four turbine/generator units.